

**WATER LABORATORY**

DELHI POLLUTION CONTROL COMMITTEE
4TH FLOOR, ISBT BUILDING, KASHIMERE GATE, DELHI-110006
visit us at <http://dpccocmms.nic.in>

Result No- DPCC/Comm/W/2216/658

14/08/2019

Date:13/08/2019

LAB REPORT

1. Name & Address of Unit : M/s.Delhi Technological University
Shahbad Daulatpur Bawana Road New Delhi
Delhi-110042
2. Sampling Location : STP Outlet
3. Date of sampling : 30/07/2019
4. Sample collected by : DPCC Lab
5. Control Measure (if any) : STP
6. Nature of sample : Grab
7. Nature of Industry : Shopping Malls, Housing / Commercial/ Office Complexes having built up area 20,000 sqm and above
8. Parameter analyzed and result

S. No.	Parameters	STP Outlet	Prescribed Standard
1	pH	7.2	5.5-9.0
2	Total Suspended Solids (TSS)	8	30.0
3	Oil and Grease	0.8	10.0
4	Dissolved Phosphate (as P)	0.6	5.0
5	Chemical Oxygen Demand(COD)	24	250.0
6	Nitrate Nitrogen	1.1	10.0
7	Bio-Chemical Oxygen Demand(BOD)[3 days at 27°C]	7	20.0
8	Ammonical Nitrogen	2.1	50.0

***All parameters are in mg/l except pH**

Dr Nandita Moitra
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist 'C'

Scientific Assistant